



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC 1322

Certificate only valid if verified on website – www.ifccertification.com

Issued by IFC Certification Ltd, part of the Kiwa UK Group

This is to certify that

Komfort Partitioning Ltd

Unit 501, Access 10,
Bentley Road,
Wednesbury, West Midlands,
WS10 8LQ
Tel: 01403 390 355

Who fabricate the following timber fire doors and or doorsets:

Own Design FD30.

at manufacturing sites A-AB6 and A-AB14, have satisfied the requirements of the SDP 01 Timber Fire Door scheme. This includes the testing of products to **BS476: Part 22**, the inspection of their Factory Production Control continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve **30 minutes integrity** are detailed on page 2 of this certificate.

Initial Certification: 12 March 2018

Revised: 31 July 2024

Valid to: 11 March 2028

Issue number: 4

David Mowatt
Head of IFC Certification /
Kiwa Group Limited

*This certificate consists of 2 pages.
Publication of this certificate is permitted.*



The production of fire-resistant timber doorsets are manufactured in accordance with assessment/ test reports referenced within the following table:

Doorset Description	Fire Rating	Assessment/Test Report
Komfort Partitioning Ltd	FD30	IFCA/97023

Signed on behalf of Kiwa UK

David Mowatt
Head of IFC Certification /
Kiwa Group Limited

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

It is the certificate holder's responsibility to ensure that the latest version/ revision of the above assessment reports are maintained as part of the audited FPC system.

Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.

CERTIFICATE

